

City Fire Protection District

Carbon Monoxide Detector Activation

NOTICE OF FINDINGS

Location of Incident _____ Incident No. _____

Time of Alarm _____ Phone _____ Time of Measurement _____

If Occupants Feel Ill: Leave Building - Seek Medical Aid!

What appliances were used in last 24 hours? _____

Gas Detection Meter Check List

Outside Reading PPM Gas Dryer PPM
Upon Entering PPM Fireplace PPM
Furnace PPM PPM
Water Heater PPM PPM
Range/Oven PPM PPM

CO Detector Information

Make _____ Model _____ Serial No. _____

Carbon Monoxide at the highest level of _____ PPM was found.

What does this reading mean?

Carbon Monoxide Symptoms	
PPM	Possible Symptoms
25	No Detectable Symptoms
200	Slight Headach, Dizziness and Nausea after 2 - 3 hours.
400	Headaches within 1 - 2 hours, Life Threatening after 3 hours.
800 +	Headaches, Dizziness, and Convulsions in less than 45 minutes. Later Unconsciousness and Death.

Any detection of CO indicates a leak.

**All appliances should be checked by a professional repair person, or
Contact NICOR gas at 1-888-642-6748**

Cary Fire Protection District _____ Date _____

Owner or Occupant Name _____ Date _____

Signature _____ Date _____

